

Lead in Water Test Results Summary:

Black Butte School - Main Building

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
SW Classroom (Blue Bay) - faucet	20520100-001CF	9/16/25	1.3	Low	N/A	N/A	N/A
SW Classroom (Blue Bay) - drinking fountain	20520100-002DW	9/16/25	ND	Non-Detect	N/A	N/A	N/A
NE Classroom (Green Ridge) - faucet	20520100-003CF	9/16/25	ND	Non-Detect	N/A	N/A	N/A
NE Classroom (Green Ridge) - drinking fountain	20520100-004DW	9/16/25	ND	Non-Detect	N/A	N/A	N/A
NW Classroom (Rose Hip) - faucet	20520100-005CF	9/16/25	2.7	Low	N/A	N/A	N/A
NW Classroom (Rose Hip) - drinking fountain	20520100-006DW	9/16/25	ND	Non-Detect	N/A	N/A	N/A
NW Classroom (Rose Hip) - Bathroom	20520100-007BF	9/16/25	0.53	Low	N/A	N/A	N/A
Staff Bathroom	20520100-008BF	9/16/25	ND	Non-Detect	N/A	N/A	N/A
Kitchen (Commons) - faucet	20520100-009KF	9/16/25	ND	Non-Detect	N/A	N/A	N/A
Kitchen (Commons) - bottle fill	20520100-010WB	9/16/25	ND	Non-Detect	N/A	N/A	N/A
Hand Wash Station - left faucet	20520100-011OT	9/16/25	0.93	Low	N/A	N/A	N/A
Hand Wash Station - center faucet	20520100-012OT	9/16/25	1	Low	N/A	N/A	N/A
Hand Wash Station - right faucet	20520100-013OT	9/16/25	1.9	Low	N/A	N/A	N/A